

INTERNATIONAL STANDARD

IEC
62305-3

First edition
2006-01

Protection against lightning –

Part 3: Physical damage to structures and life hazard

*This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.*



Reference number
IEC 62305-3:2006(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
62305-3

First edition
2006-01

Protection against lightning – **Part 3:** **Physical damage to structures** **and life hazard**

© IEC 2006 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XG**

For price, see current catalogue

CONTENTS

FOREWORD.....	11
INTRODUCTION.....	15
1 Scope.....	17
2 Normative references	17
3 Terms and definitions	19
4 Lightning protection system (LPS)	25
4.1 Class of LPS	25
4.2 Design of the LPS	27
4.3 Continuity of steelwork in reinforced concrete structures	27
5 External lightning protection system	29
5.1 General	29
5.2 Air-termination systems	29
5.3 Down-conductor systems.....	37
5.4 Earth-termination system.....	43
5.5 Components	47
5.6 Materials and dimensions	51
6 Internal lightning protection system.....	57
6.1 General	57
6.2 Lightning equipotential bonding.....	57
6.3 Electrical insulation of the external LPS	63
7 Maintenance and inspection of an LPS	65
7.1 Application of inspections	65
7.2 Order of inspections	65
7.3 Maintenance.....	65
8 Protection measures against injury to living beings due to touch and step voltages	67
8.1 Protection measures against touch voltages.....	67
8.2 Protection measures against step voltages.....	67
Annex A (normative) Positioning the air-termination system.....	69
Annex B (normative) Minimum cross-section of the entering cable screen in order to avoid dangerous sparking	81
Annex C (informative) Partitioning of the lightning current amongst down-conductors	83
Annex D (informative) Additional information for LPS in the case of structures with a risk of explosion.....	91
Annex E (informative) Guidelines for the design, construction, maintenance and inspection of lightning protection systems	103
Bibliography.....	307

Figure 1 – Loop in a down-conductor	39
Figure 2 – Minimum length l_1 of each earth electrode according to the class of LPS	43
Figure A.1 – Volume protected by a vertical air-termination rod	69
Figure A.2 – Volume protected by a vertical air-termination rod	71
Figure A.3 – Volume protected by a wire air-termination system	71
Figure A.4 – Volume protected by isolated wires combined in a mesh according to the protective angle method and rolling sphere method	73
Figure A.5 – Volume protected by non-isolated wires combined in a mesh according to the mesh method and the protective angle method	75
Figure A.6 – Design of an air-termination system according to the rolling sphere method	77
Figure C.1 – Values of coefficient k_c in the case of a wire air-termination system and a type B earth-termination system.....	85
Figure C.2 – Values of coefficient k_c in the case of a mesh air-termination system and type B earth-termination system.....	87
Figure C.3 – Examples of calculation of the separation distance in the case of a meshed air-termination system, an interconnecting ring of the down-conductors at each level and a type B earth-termination system	89
Figure E.1 – LPS design flow diagram	107
Figure E.2 – Values of coefficient k_c in case of a sloped roof with air-termination on the ridge and a type B earthing system	121
Figure E.3 – LPS design for a cantilevered part of a structure.....	123
Figure E.4 – Equipotential bonding in a structure with a steel reinforcement	127
Figure E.5 – Welded joints of reinforcing rods in reinforced concrete, if permitted.....	129
Figure E.6 – Example of clamps used as joints between reinforcing rods and conductors	131
Figure E.7 – Examples for connection points to the reinforcement in a reinforced concrete wall	133
Figure E.8 – Use of metallic facade as natural down-conductor system and connection of facade supports	141
Figure E.9 – Connection of the continuous strip windows to a metal façade covering.....	143
Figure E.10 – Internal down-conductors in industrial structures.....	149
Figure E.11– Installation of bonding conductors in reinforced concrete structures and flexible bonds between two reinforced concrete parts	153
Figure E.12 – Protective angle method air-termination design for different heights according to Table 2	161
Figure E.13 – Isolated external LPS using two isolated air-termination masts designed according to the protective angle air-termination design method	163
Figure E.14 – Isolated external LPS using two isolated air-termination masts, interconnected by horizontal catenary wire	165
Figure E.15 – Example of design of an air-termination of a non-isolated LPS by air-termination rods.....	167
Figure E.16 – Example of design of an air-termination of a non isolated LPS by a horizontal wire according to the protective angle air-termination design method	169
Figure E.17 – Protected volume of an air- termination rod or mast on a sloped surface.....	171

Figure E.18 – Design of an LPS air-termination according to the rolling sphere method, protective angle method, mesh method and general arrangement of air-termination elements	175
Figure E.19 – Design of an LPS air-termination conductor network on a structure with complicated shape	177
Figure E.20 – Space protected by two parallel air-termination horizontal wires or two air-termination rods ($r > h_t$)	179
Figure E.21 – Points at which lightning will strike a building	183
Figure E.22 – Example of design of non-isolated LPS air-termination according to the mesh method air-termination design	191
Figure E.23 – Some examples of details of an LPS on a structure with sloped tiled roofs	197
Figure E.24 – Construction of an LPS using natural components on the roof of the structure	201
Figure E.25 – Positioning of the external LPS on a structure made of insulating material e.g. wood or bricks with a height up to 60 m with flat roof and with roof fixtures	203
Figure E.26 – Construction of air-termination network on a roof with conductive covering where puncturing of the covering is not acceptable	205
Figure E.27 – Construction of external LPS on a structure of steel-reinforced concrete using the reinforcement of the outer walls as natural components	207
Figure E.28 – Example of an air-termination stud used on car park roofs	209
Figure E.29 – Air-termination rod used for protection of a metallic roof fixture with electric power installations which are not bonded to the air-termination system	211
Figure E.30 – Method of achieving electrical continuity on metallic parapet cladding	213
Figure E.31 – Metallic roof fixture protected against direct lightning interception, connected to air-termination system	219
Figure E.32 – Example of construction of lightning protection of a house with a TV antenna using the mast as an air-termination rod	223
Figure E.33 – Installation of lightning protection of metallic equipment on a roof against a direct lightning flash	225
Figure E.34 – Connection of natural air-termination rod to air-termination conductor	229
Figure E.35 – Construction of the bridging between the segments of the metallic façade plates	231
Figure E.36 – Installation of external LPS on a structure of isolating material with different roof levels	235
Figure E.37 – Examples of geometry of LPS conductors	237
Figure E.38 – Construction of an LPS using only two down-conductors and foundation earth electrodes	239
Figure E.39 – Examples of connection of earth termination to the LPS of structures using natural down-conductors (girders) and detail of a test joint	247
Figure E.40 – Construction of foundation earth ring for structures of different foundation design	255
Figure E.41 – Examples of two vertical electrodes in type A earthing arrangement	259
Figure E.42 – Meshed earth termination system of a plant	267

Figure E.43 – Examples of separation distance between the LPS and metal installations	279
Figure E.44 – Directions for calculations of the separation distance s for a worst case lightning interception point at a distance l from the reference point according to 6.3	281
Figure E.45 – Example of an equipotential bonding arrangement.....	287
Figure E.46 – Example of bonding arrangement in a structure with multiple point entries of external conductive parts using a ring electrode for interconnection of bonding bars.....	289
Figure E.47 – Example of bonding in the case of multiple point entries of external conductive parts and an electric power or communication line using an internal ring conductor for interconnection of the bonding bars	291
Figure E.48 – Example of bonding arrangement in a structure with multiple point entries of external conductive parts entering the structure above ground level.....	293
Table 1 – Relation between lightning protection levels (LPL) and class of LPS (see IEC 62305-1)	25
Table 2 – Maximum values of rolling sphere radius, mesh size and protection angle corresponding to the class of LPS.....	31
Table 3 – Minimum thickness of metal sheets or metal pipes in air-termination systems	35
Table 4 – Typical values of the distance between down-conductors and between ring conductors according to the class of LPS.....	39
Table 5 – LPS materials and conditions of use.....	49
Table 6 – Material, configuration and minimum cross-sectional area of air-termination conductors, air-termination rods and down-conductors.....	53
Table 7 – Material, configuration and minimum dimensions of earth electrodes.....	55
Table 8 – Minimum dimensions of conductors connecting different bonding bars or connecting bonding bars to the earth-termination system.....	59
Table 9 – Minimum dimensions of conductors connecting internal metal installations to the bonding bar.....	59
Table 10 – Isolation of external LPS – Values of coefficient k_i	63
Table 11 – Isolation of external LPS – Values of coefficient k_c	63
Table 12 – Isolation of external LPS – Values of coefficient k_m	65
Table B.1 – Cable length to be considered according to the condition of the screen.....	81
Table C.1 – Values of coefficient k_c	83
Table E.1 – Suggested fixing centres	193
Table E.2 – Maximum period between inspections of an LPS.....	297

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –**Part 3: Physical damage to structures and life hazard**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC national committees). The object of the IEC is to promote international cooperation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes international standards, technical specifications, technical reports, publicly available specifications (PAS) and guides (hereafter referred to as "IEC publication(s)"). Their preparation is entrusted to technical committees; any IEC national committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC national committees.
- 3) IEC publications have the form of recommendations for international use and are accepted by IEC national committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC publications is accurate, the IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC national committees undertake to apply IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to the IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC national committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC publication or any other IEC publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC publication may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International standard IEC 62305-3 has been prepared by IEC technical committee 81: Lightning protection.

The IEC 62305 series (Parts 1 to 5), is produced in accordance with the new Publications' Plan, approved by National Committees (81/171/RQ (2001-06-29)), which restructures in a more simple and rational form and updates the Publications of the IEC 61024 series, the IEC 61312 series and the IEC 61663 series.

The text of this first edition of IEC 62305-3 is compiled from and replaces

- IEC 61024-1, first edition (1990).
- IEC 61024-1-2, first edition (1998).

The text of this standard is based on the following documents:

FDIS	Report on voting
81/264/FDIS	81/269/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above Table.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 2.

IEC 62305 consists of the following parts, under the general title *Protection against lightning*:

Part 1: General principles

Part 2: Risk management

Part 3: Physical damage to structures and life hazard

Part 4: Electrical and electronic systems within structures

Part 5: Services¹

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC website "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

In the United States, based on the requirements of NFPA 780: Standard for the Installation of Lightning Protection Systems 2004 Edition and practical experience in the use of horizontal earth electrodes, the minimum length of horizontal earth electrodes is not required to be twice that required for vertical electrodes.

In France, Portugal and Spain:

- natural components cannot substitute as lightning protection components but may be used to complete/enhance the LPS;
- aluminium solid round diameters should be extended from 8 mm to 10 mm;
- stranded conductors cannot be used as down-conductors;
- diameter of solid round conductors should be extended from 16 mm to 18 mm;
- hot dip galvanized steel solid tape thickness should be extended from 2 mm to 3,5 mm.

¹ To be published

INTRODUCTION

This part of IEC 62305 deals with the protection, in and around a structure, against physical damage and injury to living beings due to touch and step voltages.

The main and most effective measure for protection of structures against physical damage is considered to be the lightning protection system (LPS). It usually consists of both external and internal lightning protection systems.

An external LPS is intended to:

- a) intercept a lightning flash to the structure (with an air-termination system);
- b) conduct the lightning current safely towards earth (using a down-conductor system);
- c) disperse the lightning current into the earth (using an earth-termination system).

An internal LPS prevents dangerous sparking within the structure using either equipotential bonding or a separation distance (and hence electrical insulation) between the external LPS (as defined in 3.2) components and other electrically conducting elements internal to the structure.

Main protection measures against injury to living beings due to touch and step voltages are intended to:

- 1) reduce the dangerous current flowing through bodies by insulating exposed conductive parts, and/or by increasing the surface soil resistivity;
- 2) reduce the occurrence of dangerous touch and step voltages by physical restrictions and/or warning notices.

The type and location of an LPS should be carefully considered in the initial design of a new structure, thereby enabling maximum advantage to be taken of the electrically conductive parts of the structure. By doing so, design and construction of an integrated installation is made easier, the overall aesthetic aspects can be improved, and the effectiveness of the LPS can be increased at minimum cost and effort.

Access to the ground and the proper use of foundation steelwork for the purpose of forming an effective earth termination may well be impossible once construction work on a site has commenced. Therefore, soil resistivity and the nature of the earth should be considered at the earliest possible stage of a project. This information is fundamental to the design of an earth-termination system and may influence the foundation design work for the structure.

Regular consultation between LPS designers and installers, architects and builders is essential in order to achieve the best result at minimum cost.

If lightning protection is to be added to an existing structure, every effort should be made to ensure that it conforms to the principles of this standard. The design of the type and location of an LPS should take into account the features of the existing structure.