

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Protection against lightning –  
Part 4: Electrical and electronic systems within structures**

**Protection contre la foudre –  
Partie 4: Réseaux de puissance et de communication dans les structures**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### Useful links:

IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Liens utiles:

Recherche de publications CEI - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [csc@iec.ch](mailto:csc@iec.ch).

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

---

**Protection against lightning –  
Part 4: Electrical and electronic systems within structures**

**Protection contre la foudre –  
Partie 4: Réseaux de puissance et de communication dans les structures**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.020; 91.120.40

ISBN 978-2-83220-130-5

<p><b>Warning! Make sure that you obtained this publication from an authorized distributor.</b></p> <p><b>Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.</b></p>
--

# CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references .....	9
3 Terms and definitions .....	10
4 Design and installation of SPM .....	13
4.1 General.....	13
4.2 Design of SPM .....	16
4.3 Lightning protection zones (LPZ).....	17
4.4 Basic SPM .....	20
5 Earthing and bonding .....	21
5.1 General.....	21
5.2 Earth-termination system.....	22
5.3 Bonding network.....	24
5.4 Bonding bars .....	28
5.5 Bonding at the boundary of an LPZ .....	29
5.6 Material and dimensions of bonding components.....	29
6 Magnetic shielding and line routing.....	30
6.1 General.....	30
6.2 Spatial shielding.....	30
6.3 Shielding of internal lines.....	30
6.4 Routing of internal lines.....	30
6.5 Shielding of external lines.....	31
6.6 Material and dimensions of magnetic shields.....	31
7 Coordinated SPD system.....	31
8 Isolating interfaces .....	32
9 SPM management .....	32
9.1 General.....	32
9.2 SPM management plan .....	32
9.3 Inspection of SPM .....	33
9.3.1 General.....	33
9.3.2 Inspection procedure .....	34
9.3.3 Inspection documentation.....	34
9.4 Maintenance.....	35
Annex A (informative) Basis of electromagnetic environment evaluation in an LPZ .....	36
Annex B (informative) Implementation of SPM for an existing structure.....	60
Annex C (informative) Selection and installation of a coordinated SPD system .....	76
Annex D (informative) Factors to be considered in the selection of SPDs.....	82
Bibliography.....	87
Figure 1 – General principle for the division into different LPZ .....	13
Figure 2 – Examples of possible SPM (LEMP protection measures).....	15
Figure 3 – Examples for interconnected LPZ.....	19
Figure 4 – Examples for extended lightning protection zones .....	20

Figure 5 – Example of a three-dimensional earthing system consisting of the bonding network interconnected with the earth-termination system .....	22
Figure 6 – Meshed earth-termination system of a plant .....	23
Figure 7 – Utilization of reinforcing rods of a structure for equipotential bonding .....	25
Figure 8 – Equipotential bonding in a structure with steel reinforcement .....	26
Figure 9 – Integration of conductive parts of internal systems into the bonding network .....	27
Figure 10 – Combinations of integration methods of conductive parts of internal systems into the bonding network .....	28
Figure A.1 – LEMP situation due to lightning strike .....	37
Figure A.2 – Simulation of the rise of magnetic field by damped oscillations .....	40
Figure A.3 – Large volume shield built by metal reinforcement and metal frames .....	41
Figure A.4 – Volume for electrical and electronic systems inside an inner LPZ n .....	42
Figure A.5 – Reducing induction effects by line routing and shielding measures .....	43
Figure A.6 – Example of SPM for an office building .....	45
Figure A.7 – Evaluation of the magnetic field values in case of a direct lightning strike .....	46
Figure A.8 – Evaluation of the magnetic field values in case of a nearby lightning strike .....	48
Figure A.9 – Distance $s_a$ depending on rolling sphere radius and structure dimensions .....	51
Figure A.10 – Types of grid-like large volume shields .....	52
Figure A.11 – Magnetic field strength $H_{1/MAX}$ inside a grid-like shield type 1 .....	53
Figure A.12 – Magnetic field strength $H_{1/MAX}$ inside a grid-like shield type 1 according to mesh width .....	54
Figure A.13 – Low-level test to evaluate the magnetic field inside a shielded structure .....	55
Figure A.14 – Voltages and currents induced into a loop formed by lines .....	56
Figure B.1 – SPM design steps for an existing structure .....	63
Figure B.2 – Possibilities to establish LPZ in existing structures .....	67
Figure B.3 – Reduction of loop area using shielded cables close to a metal plate .....	69
Figure B.4 – Example of a metal plate for additional shielding .....	70
Figure B.5 – Protection of aerials and other external equipment .....	71
Figure B.6 – Inherent shielding provided by bonded ladders and pipes .....	72
Figure B.7 – Ideal positions for lines on a mast (cross-section of steel lattice mast) .....	72
Figure B.8 – Upgrading of the SPM in existing structures .....	74
Figure C.1 – Surge voltage between live conductor and bonding bar .....	79
Figure D.1 – Installation example of test class I, class II and class III SPDs .....	83
Figure D.2 – Basic example for different sources of damage to a structure and lightning current distribution within a system .....	84
Figure D.3 – Basic example of balanced current distribution .....	85
Table 1 – Minimum cross-sections for bonding components .....	30
Table 2 – SPM management plan for new buildings and for extensive changes in construction or use of buildings .....	33
Table A.1 – Parameters relevant to source of harm and equipment .....	38
Table A.2 – Examples for $I_{0MAX} = 100$ kA and $w_m = 2$ m .....	48
Table A.3 – Magnetic attenuation of grid-like spatial shields for a plane wave .....	49
Table A.4 – Rolling sphere radius corresponding to maximum lightning current .....	51

Table A.5 – Examples for $I_{0/MAX} = 100$ kA and $w_m = 2$ m corresponding to $SF = 12,6$ dB .....	51
Table B.1 – Structural characteristics and surroundings.....	60
Table B.2 – Installation characteristics.....	61
Table B.3 – Equipment characteristics .....	61
Table B.4 – Other questions to be considered for the protection concept .....	61
Table D.1 – Preferred values of $I_{imp}$ .....	82

Copyright OVER

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PROTECTION AGAINST LIGHTNING –****Part 4: Electrical and electronic systems within structures**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-4 has been prepared by IEC technical committee 81: Lightning protection.

This second edition cancels and replaces the first edition, published in 2006, and constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- 1) Isolating interfaces capable of reducing conducted surges on lines entering the structure are introduced.
- 2) Minimum cross-sections for bonding components are slightly modified.
- 3) First negative impulse current is introduced for calculation purposes as electromagnetic source of harm to the internal systems.
- 4) Selection of SPD with regard to voltage protection level is improved to take into account oscillation and induction phenomena in the circuit downstream of SPD.
- 5) Annex C dealing with SPD coordination is withdrawn and referred back to SC 37A.

- 6) A new informative Annex D is introduced giving information on factors to be considered in the selection of SPDs.

This bilingual version (2012-06) corresponds to the monolingual English version, published in 2010-12.

The text of this standard is based on the following documents:

FDIS	Report on voting
81/373/FDIS	81/383/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted, as closely as possible, in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 62305 series, under the general title *Protection against lightning*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.



## INTRODUCTION

Lightning as a source of harm is a very high energy phenomenon. Lightning flashes release many hundreds of mega-joules of energy. When compared with the milli-joules of energy that may be sufficient to cause damage to sensitive electronic equipment in electrical and electronic systems within a structure, it is clear that additional protection measures will be necessary to protect some of this equipment.

The need for this International Standard has arisen due to the increasing cost of failures of electrical and electronic systems, caused by electromagnetic effects of lightning. Of particular importance are electronic systems used in data processing and storage as well as process control and safety for plants of considerable capital cost, size and complexity (for which plant outages are very undesirable for cost and safety reasons).

Lightning can cause different types of damage in a structure, as defined in IEC 62305-1:

- D1 injury to living beings by electric shock;
- D2 physical damage (fire, explosion, mechanical destruction, chemical release) due to lightning current effects, including sparking;
- D3 failure of internal systems due to LEMP.

IEC 62305-3 deals with the protection measures to reduce the risk of physical damage and life hazard, but does not cover the protection of electrical and electronic systems.

This Part 4 of IEC 62305 therefore provides information on protection measures to reduce the risk of permanent failures of electrical and electronic systems within structures.

Permanent failure of electrical and electronic systems can be caused by the lightning electromagnetic impulse (LEMP) via:

- a) conducted and induced surges transmitted to equipment via connecting wiring;
- b) the effects of radiated electromagnetic fields directly into equipment itself.

Surges to the structure can originate from sources external to the structure or from within the structure itself:

- surges which originate externally from the structure are created by lightning flashes striking incoming lines or the nearby ground, and are transmitted to electrical and electronic systems within the structure via these lines;
- surges which originate internally within the structure are created by lightning flashes striking the structure itself or the nearby ground.

NOTE 1 Surges can also originate internally within the structure, from switching effects, e.g. switching of inductive loads.

The coupling can arise from different mechanisms:

- resistive coupling (e.g. the earth impedance of the earth-termination system or the cable shield resistance);
- magnetic field coupling (e.g. caused by wiring loops in the electrical and electronic system or by inductance of bonding conductors);
- electric field coupling (e.g. caused by rod antenna reception).

NOTE 2 The effects of electric field coupling are generally very small when compared to the magnetic field coupling and can be disregarded.

Radiated electromagnetic fields can be generated via

- the direct lightning current flowing in the lightning channel,
- the partial lightning current flowing in conductors (e.g. in the down-conductors of an external LPS in accordance with IEC 62305-3 or in an external spatial shield in accordance with this standard).

Copyright OVER